<b>IUPUI Weekl</b>	ly Eyewash	Station	Maintenance L	og
--------------------	------------	---------	---------------	----

Year \_\_\_\_\_

Location \_\_\_\_\_

Week	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Date																		
The eyewash station is free of obstruction.																		
The eyewash is easily activated.																		
The nozzles are equipped with protective covers.																		
The covers are removed by eyewash activation																		
The water is flowing from both eyepieces.																		
The flow of water is of equal height.																		
The flow of water is clear after flushing.																		
The eyewash delivers a steady stream of water.																		
Initials																		
Week	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36
Date																		
The eyewash station is free of obstruction.																		
The eyewash is easily activated.																		
The nozzles are equipped with protective covers.																		
The covers are removed by eyewash activation																		
The water is flowing from both eyepieces.																		
The flow of water is of equal height.																		
The flow of water is clear after flushing.																		
The eyewash delivers a steady stream of water.																		
Initials																		
Week	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52		
Date																		
The eyewash station is free of obstruction.																		
The eyewash is easily activated.																		
The nozzles are equipped with protective covers.																		
The covers are removed by eyewash activation																		
The water is flowing from both eyepieces.																		
The flow of water is of equal height.																		
The flow of water is clear after flushing.																		
The eyewash delivers a steady stream of water.																		
Initials																		